

FIRE EXTINGUISHER INSTALLATION & COMPLETION CERTIFICATE

Certificate No: 06082026

Date: 06.08.2026

1. CLIENT & SITE DETAILS

Client / Company Name:	Aura Edify Global School
Site / Premises Address:	Chappara,kodungallur
Contact Person & Phone:	9447441002
Building Occupancy Type:	EDUCATIONAL BUILDING

2. SCHEDULE OF FIRE EXTINGUISHERS INSTALLED

Sl. No.	Extinguisher Type	Capacity	Qty	Location / Floor	Serial / ID Nos.
1	ABC Dry Powder	4 kg	2	Ground Floor - Main Entrance	10258
2	CO2 (Carbon Dioxide)	4.5 kg	1	Electrical / Server Room	102548
3	ABC Dry Powder	4 KG	1	Storage / Kitchen	102458
4	CO2 (Carbon Dioxide)	4.5 kg	1	Storage / Kitchen	102487
5.	ABC Dry Powder	4 KG	3	FIRST FLOOR	102483
				SECOND FLOOR	102484
				THIRD FLOOR	102485



This is to certify that the fire extinguishers listed above have been successfully supplied, inspected, and installed at the specified premises in accordance with the required safety standards.

- **Standards Compliance:** Installed in accordance with IS 2190 / NBC standards and local Fire & Rescue Department guidelines.
- **Mounting & Accessibility:** All units are securely mounted on wall brackets/stands at proper height levels, unobstructed, easily accessible, and fully charged.
- **Signage & Tagging:** Inspection tags and operational instruction stickers have been properly affixed to each unit.

4. SERVICE & INSPECTION DATES

Date of Installation:	05.08.2026
Next Periodic Inspection Due:	05.08.2027 (Quarterly / Half-Yearly)



For POWER TECH TECHNOLOGYS

Authorized Signature & Company Seal

Technician / Engineer Name: [Name]
Designation: [Service Engineer / Manager]
Contact No: [Phone Number]